

**TATA MEMORIAL CENTRE**  
**Advanced Centre for Treatment, Research and Education in Cancer**

**Technical Specification of: 12V, 65AH SMF Battery(QTY-32 No)**

**TECHNICAL REQUIREMENT:**

Battery should be suitable for 100KVA Consul UPS .

L1 identification will be based on

{(Battery price + Installation charges+ Accessories price)- Buyback Price of old batteries}

**Name of the Manufacturer:** \_\_\_\_\_

**Name of the Vendor:** \_\_\_\_\_

Sr. No.	Description of item	Compliance
	<b>Model Name:</b>	
	<b>Make:</b>	
1	Battery should be 12V, 65AH capacity	
2	Battery should be sealed and maintenance free	
3a	Charging voltage and current setting should be : Float voltage:2.27V/Cell	
3b	Boost voltage:2.35V/Cell	
4	Battery should be compatible for Consul make 100KVA UPS	
6	Batteries size: Should not exceed 33cm (L) X 17cm (W) and 35cm (H) It should be fit in the present battery rack with the UPS.	
7	Installation charges should be included in the battery price.	
8	Any additional accessories required for the installation of batteries, then it should be quoted with the batteries.	
9	Vendor should quote a buyback price for 64 nos. of old batteries with the same specification.	
10	The vendor can be check the site to see the feasibility of installation before send the quotation to identify additional requirement , if any.	
	<b>Warranty: 2 years replacement</b>	
	<b>Free Service: NA</b>	